

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 221-2020
Test Method to Field-Measure and Score the Cooling and Heating
Performance of an Installed Unitary HVAC System**

August 5, 2021

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 221-2020. The first printing of Standard 221-2020 is identified as “Product Code: 86644 8/20” on the outside back cover

Page Erratum

35 **Table A-3 Generic Heat-Pump Capacity Adjustment.** Replace Table A-3 with the following table:

Table A-3 Generic Heat-Pump Capacity Adjustment

Heat Pump Capacity Adjustment Factor C_{HP} as a function of Outside Air Dry Bulb Temperature			
Outside Air DB °F (°C)	C_{HP}	Outside Air DB °F (°C)	C_{HP}
35°F (1.7°C)	0.78	51°F (10.6°C)	1.07
36°F (2.2°C)	0.80	52°F (11.1°C)	1.09
37°F (2.8°C)	0.82	53°F (11.7°C)	1.11
38°F (3.3°C)	0.84	54°F (12.2°C)	1.12
39°F (3.9°C)	0.85	55°F (12.8°C)	1.14
40°F (4.4°C)	0.87	56°F (13.3°C)	1.16
41°F (5°C)	0.89	57°F (13.9°C)	1.18
42°F (5.6°C)	0.91	58°F (14.4°C)	1.19
43°F (6.1°C)	0.93	59°F (15°C)	1.21
44°F (6.7°C)	0.95	60°F (15.6°C)	1.23
45°F (7.2°C)	0.96	61°F (16.1°C)	1.24
46°F (7.8°C)	0.98	62°F (16.7°C)	1.26
47°F (8.3°C)	1.00	63°F (17.2°C)	1.27
48°F (8.9°C)	1.02	64°F (17.8°C)	1.29
49°F (9.4°C)	1.04	65°F (18.3°C)	1.31
50°F (10°C)	1.05	66°F (18.9°C)	1.32