

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 29-2009
Method of Testing Automatic Ice Makers**

March 21, 2012

The corrections listed in this errata sheet apply to the first printing of ANSI/ASHRAE Standard 29-2009 identified on the outside back cover as “Product Code: 86077 3/09”. Shaded item has been added since the previously published errata sheet dated April 12, 2010 was distributed.

Page	Erratum												
Inside Cover	<p>In the inside cover, top of page, change the cognizant TC from TC 10.2 to TC 10.7 as follows:</p> <p style="text-align: center;">Cognizant TC: TC 10.7, Commercial Food and Beverage Cooling Display and Storage</p>												
4	<p>8.2 Capacity Test. In Section 8.2a change “(See Sections 6.2.1 and 6.2.2.)” to “(See Sections 7.2 and 7.2.1.)”.</p>												
5	<p>Table A1 - Table for Recording Data Gathered.</p> <ul style="list-style-type: none"> - In item 10 of Table A1 change the equation from “(9) x (5) x 4.19 [(9) x (5)]” to read as follows: <table style="margin-left: 40px; border: none;"> <tr> <td style="padding-right: 20px;">$4.19^* \times [(9) \times (5)]$</td> <td>(SI units)</td> </tr> <tr> <td>$1.0^* \times [(9) \times (5)]$</td> <td>(I-P units)</td> </tr> </table> - In item 13 of Table A1 change the equation from “(8) x (3) x 4.19 {[(8) – (32°F) x (3) }” to read as follows: <table style="margin-left: 40px; border: none;"> <tr> <td style="padding-right: 20px;">$4.19^* \times [(8) \times (3)]$</td> <td>(SI units)</td> </tr> <tr> <td>$1.0^* \times (3) \times [(8) - (32^\circ\text{F})]$</td> <td>(I-P units)</td> </tr> </table> - In item 20(d) of Table A1 change the equation from “(20b) x (6) / [(20a) x (20c)] = (20b) x (6) x 4.19 / (20a) x (20c)” to read as follows: <table style="margin-left: 40px; border: none;"> <tr> <td style="padding-right: 20px;">$(20b) \times (6) \times 4.19^* / (20a) \times (20c)$</td> <td>(SI units)</td> </tr> <tr> <td>$(20b) \times (6) \times 1.0^* / (20a) \times (20c)$</td> <td>(I-P units)</td> </tr> </table> - In item 20(d) of Table A1 delete “temp. difference” from the Units column so it reads: <p style="margin-left: 40px;">kJ (Btu) / min / °C (°F)</p> - At the bottom of Table A1 add the following note: 	$4.19^* \times [(9) \times (5)]$	(SI units)	$1.0^* \times [(9) \times (5)]$	(I-P units)	$4.19^* \times [(8) \times (3)]$	(SI units)	$1.0^* \times (3) \times [(8) - (32^\circ\text{F})]$	(I-P units)	$(20b) \times (6) \times 4.19^* / (20a) \times (20c)$	(SI units)	$(20b) \times (6) \times 1.0^* / (20a) \times (20c)$	(I-P units)
$4.19^* \times [(9) \times (5)]$	(SI units)												
$1.0^* \times [(9) \times (5)]$	(I-P units)												
$4.19^* \times [(8) \times (3)]$	(SI units)												
$1.0^* \times (3) \times [(8) - (32^\circ\text{F})]$	(I-P units)												
$(20b) \times (6) \times 4.19^* / (20a) \times (20c)$	(SI units)												
$(20b) \times (6) \times 1.0^* / (20a) \times (20c)$	(I-P units)												

*specific heat of water, $c_p = 4.19 \text{ kJ/kg}\cdot^\circ\text{C}$ (1.0 Btu/lb $\cdot^\circ\text{F}$)
(temp. difference)