

**ERRATA SHEET FOR ADDENDUM c to
ANSI/ASHRAE STANDARD 52.2-2017
Method of Testing General Ventilation Air-Cleaning Devices
for Removal Efficiency by Particle Size**

September 9, 2024

The corrections listed in this errata sheet apply to all copies of ANSI/ASHRAE Addendum c to ANSI/ASHRAE Standard 52.2-2017. The first printing is identified on the outside back cover as “1/22”.

Page Erratum

- 3-4 L7.1 Calculation of Uncorrected Removal/Inactivation Efficiency.** Revise Equations L-1 and L-3 to relocate the “× 100%” outside the parenthesis as shown below.

...

$$\eta (\%) = \left(1 - \frac{C_{downstream}}{C_{upstream}}\right) \times 100\% \quad (L-1)$$

...

$$\eta_{Corr}(\%) = \left(1 - \frac{C_{downstream}}{C_{upstream} \times P_{no \ device}}\right) \times 100\% \quad (L-3)$$

...