

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 62.1-2025
Ventilation and Acceptable Indoor Air Quality**

August 27, 2026

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 62.1-2025. The first printing is identified on the outside back cover as “Product code: 86009 11/25”. Shaded items have been added since the previously published errata sheet dated January 27, 2026 was distributed.

NOTICE: ASHRAE now has a list server for Standing Standards Project Committee 62.1 (SSPC 62.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Project Committee List Servers** on the Standards and Guidelines section of the ASHRAE website at <https://www.ashrae.org/technical-resources/free-resources/listserves>.

Page Erratum

- 25 6.2.4.4 Outdoor Air Intake.** Revise Equation as shown below. Corrections are highlighted in yellow.

$$V_{ot} = V_{ow}/E_v \times E_p \quad (6-10)$$

- 39 Table 8-1 Minimum Inspection, Verification, and Validation Activity and Frequency for Ventilation Systems and Associated Components (*Continued*).** Correct reference to “Table 6-5” to “Table 6-6” in Informative Notes as shown below:

Task No.*	Related Section	Inspection, Verification, Validation Task	Frequency
16a	6.3.1 6.3.3.2 7.3	For systems designed per the <i>Indoor Air Quality Procedure (IAQP)</i> , verify if changes to the occupancy, changes to space utilization, new procedures, new components, refurbishments, or renovations have been made. If so, see Task No. 16b. Informative Notes: 1. New procedures or components in the space such as new furniture, printers, computers, cleaning chemicals, or other additions could increase the compounds listed in Table 6-66-5 . 2. Refurbishment of carpets, paint, tiles, windows, or other additions could increase the compounds listed in Table 6-66-5 .	Every 2 years