

**ERRATA SHEET FOR  
ANSI/ASHRAE STANDARD 62.1-2025  
Ventilation and Acceptable Indoor Air Quality**

**January 27, 2026**

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 62.1-2025. The first printing is identified on the outside back cover as “Product code: 86009 11/25”.

**NOTICE:** ASHRAE now has a list server for Standing Standards Project Committee 62.1 (SSPC 62.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Project Committee List Servers** on the Standards and Guidelines section of the ASHRAE website at <https://www.ashrae.org/standards-research--technology/standards--guidelines/standards-activities/project-committee-list-servers>.

**Page**   **Erratum**

**25**   **6.2.4.4 Outdoor Air Intake.** Revise Equation as shown below. Corrections are highlighted in yellow.

$$V_{ot} = V_{ou}/E_v \times E_p \quad (6-10)$$