

**ERRATA SHEET FOR ANSI/ASHRAE ADDENDUM i
ANSI/ASHRAE STANDARD 62.1-2022
Ventilation and Acceptable Indoor Air Quality**

March 10, 2025

The corrections listed in this errata sheet apply to ANSI/ASHRAE Addendum i to ANSI/ASHRAE Standard 62.1-2022. The first printing is identified on the outside back cover as “10/24”.

NOTICE: ASHRAE now has a list server for Standing Standards Project Committee 62.1 (SSPC 62.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Project Committee List Servers** on the Standards and Guidelines section of the ASHRAE website at <https://www.ashrae.org/standards-research--technology/standards--guidelines/standards-activities/project-committee-list-servers>.

Page Erratum

- 1 Table 7-2 Direct Reading Instruments Minimum Specifications.** Revise Table 7-2 as shown below.

(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

Table 7-2 Direct Reading Instruments Minimum Specifications

	Ozone	PM_{2.5}	Carbon Monoxide	Formaldehyde^a
Accuracy (±)	5 ppb	Greater of 5 µg /m ³ or 20% of reading	Greater of 3 ppm or 20% of reading	<u>2% full scale within calibrated linearity range</u> 0.1 ppb
Resolution (±)	1 ppb	5 µg/m ³	1 ppm	<u>0.1 ppb</u> 2% full scale within calibrated linearity range

^a. Include the “calibrated linearity range” in all reports.