

ERRATA SHEET FOR FIRST PRINTING
ANSI/ASHRAE STANDARD 72-2005
Method of Testing Commercial Refrigerators and Freezers

September 10, 2009

The corrections listed in this errata sheet apply to the first printing of ANSI/ASHRAE Standard 72-2005. The outside back cover marking identifying the first printing is “86194 PC 8/05”. The shaded item has been added since the previously published errata sheet dated January 17, 2006 was distributed.

Page Erratum

- 4 Section 4.1.2 Wet Bulb.** Change the first sentence to read as follows:
(Note: Additions are shown in underline.)

The average test-room wet-bulb temperature shall be $18.0^{\circ}\text{C} \pm 1.0^{\circ}\text{C}$ ($64.4^{\circ}\text{F} \pm 1.8^{\circ}\text{F}$), when measured in accordance with Section 6 of this standard.

- 7 Section 7.1.3 General.** Revise the second sentence in Section 7.1.3 as follows:
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

7.1.3 General. For the test, the provisions of Section 7.2 through 7.9 shall be followed for remote refrigerators. For self-contained refrigerators, the test shall follow the provisions of Sections 7.2, 7.3, 7.4, 7.7, and 7.8, ~~and 7.9.~~