

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 90.2-2001
Energy-Efficient Design of Low-Rise Residential Buildings**

January 17, 2006

The corrections listed in this errata sheet apply to the first printing of ANSI/ASHRAE Standard 90.2-2001 date coded “2/02” on the outside back cover. Shaded item has been added since the previously published errata sheet dated February 19, 2004 was distributed.

Page Erratum

- | | |
|----|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 42 | Table 6-4a Minimum Pipe Insulation for Pipes \leq 2 in. In footnote “a” change “See 6.3.2.3.1” to read “See 6.3.2.1.2” and in footnote “b” change “See 6.3.2.2” to read “See 6.3.2.1.1”. |
| 52 | Section 8.8.3.2 Window Internal Shading. In the last sentence of Section 8.8.3.2 add the word “and” immediately following “cooling load” so that it reads: “All operable shading and drapes shall be closed when the air conditioning is running to meet a cooling load and at night, but open during the rest of the day.” |