

**ERRATA SHEET FOR  
ANSI/ASHRAE STANDARD 90.2-2018  
Energy-Efficient Design of Low-Rise Residential Buildings**

**December 9, 2024**

The corrections listed in this errata sheet apply to ANSI/ASHRAE/IES Standard 90.2-2018 edition. The first printing is identified on the outside back cover of the standard as “Product code: 86256 12/18”.

**Page(s)   Erratum**

- 12      7.4.3.3 Maximum Volume.** Revise Section 7.4.3.3 to change “0.125 gal (4.73 L)” to “0.125 gal (0.473 L)” as shown below.

*(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)*

**7.4.3.3 Maximum Volume.** The maximum volume between the nearest source of hot water and the plumbing fixture or appliance shall not exceed 0.125 gal (0.473 ~~4.73~~ L). The volume shall be the sum of the internal volumes of pipe, fittings, valves, meters, and manifolds between the nearest source of hot water and the termination of the fixture supply pipe. The volume contained within fixture shutoff valves, within flexible water supply connectors to a fixture fitting, and within a fixture fitting shall not be included in the water volume determination. Where hot water is supplied by a recirculating system or heat-traced piping, the volume shall include the portion of the fitting on the branch pipe that supplies water to the fixture. The maximum length of a branch containing a single pipe diameter shall be determined by Table 7-3. The maximum length of branch piping containing more than one pipe diameter shall be based on the volume contained in each segment such that the combined volume does not exceed 0.125 gal (0.473 ~~4.73~~ L).