

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 90.4-2019
Energy Standard for Data Centers**

March 23, 2021

The corrections listed in this errata sheet apply to all copies of ANSI/ASHRAE Standard 90.4-2019. The first printing is identified on the outside back cover as “Product code: 86302 11/19”.

Page Erratum

- 44** **Table C-2 Calculation of Incoming Electrical Service Segment of (ELC) Based on Circuit Losses at 100% Design Load⁹—Low-Voltage Feeder Input Power Requirement (Derived from End Power Requirement to UPS Input).** Revise the equations in the columns shown below. Changes highlighted in yellow.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

Loss, V	End, V	Voltage Loss, %
1.05	479	0.22%
<i>h</i>	<i>i</i>	<i>j</i>
<i>g</i> <u><i>h</i></u> = <i>b</i> × <i>g</i>	<i>h</i> <u><i>i</i></u> = <i>a</i> ₁ − <i>h</i>	<i>i</i> <u><i>j</i></u> = <i>h</i> / <i>a</i> ₁ × 100%

- 45** **Table C-4 Calculation of Incoming Electrical Service Segment of (ELC) Based on Circuit Losses at 100% Design Load⁹— Medium-Voltage Feeder Input Power Requirement at Utility Service Point (Derived from Table C-3 Input Power Requirement).** Revise the equations in the columns shown below. Changes highlighted in yellow.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

Resist Ohms	End Power, kVA
0.0026	478.82
<i>g</i>	<i>k</i>
<i>f</i> <u><i>g</i></u> = <i>d</i> × <i>f</i> / 1000	<i>j</i> <u><i>k</i></u> = Table C-3 <i>c</i>