

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2022, ADDENDUM m
Designation and Safety Classification of Refrigerants

August 27, 2024

The corrections listed in this errata sheet apply to Addendum m to ANSI/ASHRAE Standard 15-2022. The identifying footer of all number pages include the title “ANSI/ASHRAE Addendum m to ANSI/ASHRAE Standard 15-2022.”

Page Erratum

- 3** **7.2.3.2.2** Replace RCL with LFL as shown highlight below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

$$A_{vent} = \frac{m_{rel} - m_{room}}{\underline{RCL} \underline{LFL} \times 0.417} \times \sqrt{\frac{A}{g \times m_{room}}} \times \frac{M_r}{M_r - M_a}$$

$$A_{vent} = \frac{m_{rel} - m_{room}}{\underline{RCL} \underline{LFL} \times 104} \times \sqrt{\frac{A}{g \times m_{room}}} \times \frac{M_r}{M_r - M_a}$$

- 3** **9. (9-4)** Remove equal sign as shown highlighted below
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

$$r_w = \frac{c_a}{c_r} \underline{=} \sqrt{\frac{T_r}{T_a}} \sqrt{\frac{M_a}{M_r}}$$