

**INTERPRETATION IC 62.1-2013-6 OF  
ANSI/ASHRAE STANDARD 62.1-2013  
VENTILATION FOR ACCEPTABLE INDOOR AIR QUALITY**

Approved: March 16, 2017

**Request from:** Trevor M. Uitvlugt, MCW Hemisphere Ltd., 2400, 10020 - 100 Street NW, Edmonton, Alberta T5P2C8.

**Reference:** This request for interpretation refers to the requirements presented in ANSI/ASHRAE Standard 62.1-2013, Section 6.2.7.1.1, regarding DCV and the use of CO<sub>2</sub> sensors in return air ductwork at the system level.

**Background:** There are currently provisions in the standard for using space CO<sub>2</sub> sensors to modulate the ventilation air to a zone for Demand Control Ventilation (DCV). A CO<sub>2</sub> sensor in the space allows the primary air in a zone to be modulated between minimum and maximum flows to maintain a CO<sub>2</sub> setpoint. Minimum ventilation flow for DCV in a zone is no less than the Breathing Zone Outdoor Airflow (area related portion):  $Ra \times Az$ .

For an air system serving multiple zones, there does not seem to be direction for expanding DCV to the System Level. As building occupant levels ( $Ps$ ) increase or decrease during the day, the Outdoor air intake flow required ( $Vot$ ) should also be allowed to increase or decrease accordingly.

**Interpretation:** By adding CO<sub>2</sub> sensors to the Return air of a multiple zone air system, the actual amount System Occupants ( $Ps$ ) can be estimated in a similar way to a DCV zone with a CO<sub>2</sub> sensor estimates the Zone Population ( $Pz$ ).

CO<sub>2</sub> sensor in the return air would allow the Outdoor air in a zone to be modulated between minimum and maximum flows to maintain a CO<sub>2</sub> setpoint. Minimum Outdoor air flow for DCV in a system would be no less than the sum of all area components:  $\text{Sum}(Ra \times Az)$ .

**Question:** Is this interpretation correct?

**Answer:** No

**Comments:** In addition to total number of people ( $Ps$ ), one must also identify in which zone(s) they reside. Multiple zone process requires that ventilation be at least minimum for each zone.